

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Notice of Surface Water Monitoring, Routine Major Violation by the ECWSD
January 1, 2024

The City of Eastland, PWS ID 0670002 purchases treated water from the **Eastland County Water Supply District, PWS ID 0670019** which has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems that treat surface water and/or ground water under the direct influence of surface water are required to submit monthly operating reports with operational data of the treatment, disinfection and quality of the water provided to their customers.

ECWSD failed to monitor and/or report all data needed to evaluate the membrane filters, Turbidity and Chloramine.

These violations occurred in the monitoring periods of July, August and September 2023

Results of regular monitoring are an indicator of whether or not your drinking water is safe. ECWSD did not complete all monitoring and/or reporting for surface water constituents, and therefore TCEQ cannot be sure of the safety of your drinking water during this time.

We are taking the following actions to address this issue:

The ECWSD has modified its standard operating procedure to create a back-up of the data on all daily reporting collected by our (SCADA) Supervisory Control and Data Acquisition system.

Please share this information with other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. If you have questions regarding this matter, you may contact **JJ Oznick at 254-629-8321**.